

Solid Air Climate Solutions casing leakage test sheet According to standard NEN-EN 1751-2014

Date:	2/27/2025	Test reference number:	25-6-01
Exp. Date:	2/27/2028	Tested by:	GV
Place:	Solid Air Climate Solutions B.V.	Witness by:	HV

Model (Name/Type): **Jaloezieklep KIVT 400x400** Result: **ATC3 (C)**

Measurement conditions <input type="checkbox"/>	
Air temperature (C°)	19
Atmospheric pressure (hPa)	1015
Correction factor	1.000
Case Width (m)	0.4
Case height (m)	0.4
Case Length (m)	0.12
Duct surface (real) (m ²)	0.19
Duct surface (virtual) (m ²)*	1.60
<small>* Case length 1m is used in calculations when real Case length <1m (As specified by LUKA)</small>	



SOLID AIR
CLIMATE SOLUTIONS


Scheepswervenweg 1
9608 PD Westerbroek
Tel: +31 598 36 12 21
www.solid-air.com

Measurement equipment	
Brand	Lindab
Air leakage tester type	LT 600
Serial No.	662
Adapter (- / 0,3 / 3,0)	0.3

Test duration 60 sec.		
Visual deformation?	N	
Max. test pressure	1000	Pa
TÜV certificate	P-97/52-30	

Reading					NEN-EN 1751-2014			
	Static Pressure	Measured Leakage	Corrected Leakage	Leakage Duct surface	ATC5 (A)	ATC4 (B)	ATC3 (C)	ATC2 (D)
	(Pa)	(l/s)	(l/s)	(l/s/m ²)	(l/s/m ²)	(l/s/m ²)	(l/s/m ²)	(l/s/m ²)
1	250	0.087	0.087	0.054	0.98	0.33	0.11	0.04
2	400	0.121	0.121	0.076	1.33	0.44	0.15	0.05
3	750	0.190	0.190	0.119	2.00	0.67	0.22	0.07
4	1000	0.234	0.234	0.146	2.41	0.80	0.27	0.09

Classification of casing leakage



* Classification result is the same for all models as tested model, unless indicated otherwise.

Approved and certified by



Solid Air Climate Solutions casing leakage test sheet

According to standard NEN-EN 1751-2014

Date:	2/27/2025	Test reference number:	25-6-02
Exp. Date:	2/27/2028	Tested by:	GV
Place:	Solid Air Climate Solutions B.V.	Witness by:	HV

Model (Name/Type): **Jaloezieklep KIVT 500x300** Result: **ATC3 (C)**

Measurement conditions <input type="checkbox"/>	
Air temperature (C°)	19
Atmospheric pressure (hPa)	1015
Correction factor	1.000
Case Width (m)	0.5
Case height (m)	0.3
Case Length (m)	0.12
Duct surface (real) (m ²)	0.19
Duct surface (virtual) (m ²)*	1.60
<small>* Case length 1m is used in calculations when real Case length <1m (As specified by LUKA)</small>	



Solid Air
CLIMATE SOLUTIONS


Scheepswervenweg 1
9608 PD Westerbroek
Tel: +31 598 36 12 21
www.solid-air.com

Measurement equipment	
Brand	Lindab
Air leakage tester type	LT 600
Serial No.	662
Adapter (- / 0,3 / 3,0)	0.3

Test duration 60 sec.		
Visual deformation?	N	
Max. test pressure	1000	Pa
TÜV certificate	P-97/52-30	

Reading					NEN-EN 1751-2014			
	Static Pressure	Measured Leakage	Corrected Leakage	Leakage Duct surface	ATC5 (A)	ATC4 (B)	ATC3 (C)	ATC2 (D)
	(Pa)	(l/s)	(l/s)	(l/s/m ²)	(l/s/m ²)	(l/s/m ²)	(l/s/m ²)	(l/s/m ²)
1	250	0.082	0.082	0.051	0.98	0.33	0.11	0.04
2	400	0.110	0.110	0.069	1.33	0.44	0.15	0.05
3	750	0.166	0.166	0.104	2.00	0.67	0.22	0.07
4	1000	0.201	0.201	0.126	2.41	0.80	0.27	0.09

Classification of casing leakage



* Classification result is the same for all models as tested model, unless indicated otherwise.

Approved and certified by



Solid Air Climate Solutions casing leakage test sheet According to standard NEN-EN 1751-2014

Date:	2/27/2025	Test reference number:	25-6-03
Exp. Date:	2/27/2028	Tested by:	GV
Place:	Solid Air Climate Solutions B.V.	Witness by:	HV

Model (Name/Type): **Jaloezieklep KIVT 750x350** Result: **ATC3 (C)**

Measurement conditions <input type="checkbox"/>	
Air temperature (C°)	19
Atmospheric pressure (hPa)	1015
Correction factor	1.000
Case Width (m)	0.75
Case height (m)	0.35
Case Length (m)	0.12
Duct surface (real) (m ²)	0.26
Duct surface (virtual) (m ²)*	2.20
<small>* Case length 1m is used in calculations when real Case length <1m (As specified by LUKA)</small>	



Solid Air
CLIMATE SOLUTIONS


Scheepswervenweg 1
9608 PD Westerbroek
Tel: +31 598 36 12 21
www.solid-air.com

Measurement equipment	
Brand	Lindab
Air leakage tester type	LT 600
Serial No.	662
Adapter (- / 0,3 / 3,0)	0.3

Test duration 60 sec.		
Visual deformation?	N	
Max. test pressure	1000	Pa
TÜV certificate	P-97/52-30	

Reading					NEN-EN 1751-2014			
	Static Pressure	Measured Leakage	Corrected Leakage	Leakage Duct surface	ATC5 (A)	ATC4 (B)	ATC3 (C)	ATC2 (D)
	(Pa)	(l/s)	(l/s)	(l/s/m ²)	(l/s/m ²)	(l/s/m ²)	(l/s/m ²)	(l/s/m ²)
1	250	0.144	0.144	0.065	0.98	0.33	0.11	0.04
2	400	0.201	0.201	0.091	1.33	0.44	0.15	0.05
3	750	0.312	0.312	0.142	2.00	0.67	0.22	0.07
4	1000	0.385	0.385	0.175	2.41	0.80	0.27	0.09

Classification of casing leakage



* Classification result is the same for all models as tested model, unless indicated otherwise.

Approved and certified by

